

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	HVAC Control Thermostat
Name and address of the applicant	Crestron Electronics Inc 15 Volvo Drive Rockleigh, NJ 07647 United States of America
Name and address of the manufacturer	Crestron Electronics Inc 15 Volvo Drive Rockleigh, NJ 07647 United States of America
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 Crestron Electronics Inc 88 Ramland Rd Orangeburg, NY 10962 United States of America
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	24VDC, 0.28A, Operating temperature: 0-40°C Relay rating: 230mW maximum @ 24VDC
Trademark (if any)	 CRESTRON
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	DIN-THSTAT
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60730-1:2013/AMD1:2015, IEC 60730-2-9:2015/AMD1:2018 National differences: EU Group Differences, CA, US
As shown in the Test Report Ref. No. which forms part of this Certificate	103669419DAL-001

This CB Test Certificate is issued by the National Certification Body

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Suite F, Arlington Heights, IL 60005, United States of America

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Jabil Circuit de Mexico S de RL de CV
Technology Park #420, Carretera Nogales Km 13.5, Av.
Guadalupe #225
Zapopan Jal Na
Mexico

EPI de Mexico S de RL de CV
Boulevard Independencia 1451 Int. 2
Parque Industrial Intermex Oriente
Juarez Chih 32599
Mexico

This CB Test Certificate is issued by the National Certification Body

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Suite F, Arlington Heights, IL 60005, United States of America

