

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic switch

Name and address of the applicant

Crestron Electronics Inc.
15 Volvo drive
NJ 07647 ROCKLEIGH
UNITED STATES

Name and address of the manufacturer

Crestron Electronics Inc.
15 Volvo drive
NJ 07647 ROCKLEIGH
UNITED STATES

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

CRESTRON

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

DIN-1DIMU4

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60669-1:2017
IEC 60669-2-1:2002+A1:2008+A2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

156075-722700

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 21/01/2020

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature: 
Julien Gauthier
Certification Officer

ANNEX

Name and address of the factories:**JABIL CIRCUIT DE MEXICO S DE R L DE C V**

Technology Park #420
Carretera Nogales Km 13.5
Av. Guadalupe #225
45010 Zapopan
Jalisco MEXICO

EPI de Mexico S de RL de CV

Boulevard Independencia #1451 Int.2
Parque Industrial Intermex Oriente
CP 32599 Juarez
Chihuahua MEXICO

Crestron Electronics Inc.

88 Ramland Rd,
Orangeburg, NY 10962
USA



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 21/01/2020



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

ANNEX

RATINGS AND MAIN CHARACTERISTICS

Pattern number	1
Contact opening (gap)	without (semiconductor switching device)
Protection degree	IP20
Method of actuating	push-button
Method of mounting	panel-type
Method of installation	design A - B
Type of terminals	screw-type
Flexible cable outlet	without
Kind of load controlled	incandescent lamps, externally ballasted fluorescent lamps, electronic step-down converter for extra low-voltage incandescent lamps, iron core transformer for extra low-voltage incandescent lamps
Rated current (A) - Rated load (VA or W)	5A max / output ; 10A total ; 4 loads total
Rated voltage (V)	120-240V~
Rated frequency (Hz)	50/60Hz



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 21/01/2020



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer