

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product Produit	Energy Management Equipment
Name and address of the applicant Nom et adresse du demandeur	CRESTRON ELECTRONICS INC 15 VOLVO DR ROCKLEIGH NJ 07647, USA
Name and address of the manufacturer Nom et adresse du fabricant	CRESTRON ELECTRONICS INC 15 VOLVO DR ROCKLEIGH NJ 07647, USA
Name and address of the factory Nom et adresse de l'usine	CRESTRON ELECTRONICS INC 15 VOLVO DR ROCKLEIGH NJ 07647 USA
Note: <i>When more than one factory, please report on page 2</i> Note: <i>Lorsque il y a plus d'une usine, veuillez utiliser la 2^{eme} page</i>	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics Valeurs nominales et caractéristiques principales	See Page 2
Trademark (if any) Marque de fabrique (si elle existe)	Crestron
Type of Manufacturer's Testing Laboratories used Type de programme du laboratoire d'essais constructeur	
Model / Type Ref. Ref. De type	GLS-EM-MCU, GLS-EM-CTI, See Page 2
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire,, peuvent être indiqués sur la 2 ^{eme} page	National Differences specified in the CB Test Report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la	IEC 61010-1(ed.2)
As shown in the Test Report Ref. No. which forms part of this Certificate Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat	E353842-A1-CB-1 issued on 2012-10-19

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2012-10-19

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

US-19978-UL

Model Details:

Accessories - GLS-EM-CTI (6 or 21 Channels) may be followed by 2 or 3, may be followed by P, may be followed by 1, 2 or 6, may be followed by 1 or 5

Ratings:

Input (CTRL) = 100-347 Vac, 50/60Hz, 0.18 A max

Input/Output(LOAD)= 24 Vdc pulse input

Load Type And Ratings = Current transformer signal rated 333 mVac max

Accessory Input Rating = 6 Vdc, 200 mA max

Additional information (if necessary)

Information complémentaire (si nécessaire)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2012-10-19

Signature:

Jolanta M. Wroblewska